

OFFICE OF THE SUPERINTENDING CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT LABORATORY , JODHPUR
BACTERIOLOGICAL EXAMINATION REPORT

E-mail : phedregionallabjodhpur@gmail.com Web.: indiawater.gov.in Phone No. 0291 – 2651767

No.Lab./Tech./ (Bact.)/ 2023-24/ 789
To,

Date: 30-03-2024

CAREER POINT WORLD SCHOOL
VIJAYRAJE NAGAR, NEW HIGH COURT
SHATABDI CIRCLE, JHALAMAND
JODHPUR

Distt:- Jodhpur
Tehsil:- Jodhpur
Sample Collected by - Vinod


**SAMPLE WAS NOT COLLECTED
BY THE LABORATORY**

Not for Legal Purpose

Reference: NIL /Date 27.03.2024

Sample No.	Date&Time of Collection	Date of Examination	Residual Chlorine mg/l	Particulars of Samples	Coliform organism MPN per 100 ml.
PB-51	28.03.2024	28.03.2024	-	R.O. WATER CAREER POINT WORLD SCHOOL	0

Remarks: (1)Satisfactory : PB 51
(2)Suspicious :
(3)Unsatisfactory :


Superintending Chemist
P.H.E.D. Lab.,Jodhpur

No.Lab./Tech./ (Bact.)/ 2023-24/
CC : 1.The Chief Chemist,P.H.E.D.,Raj. Jaipur

Date:

Superintending Chemist
P.H.E.D. Lab.,Jodhpur

OFFICE OF THE SUPERINTENDING CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT REGIONAL LABORATORY JODHPUR (Raj.)
REPORT OF THE CHEMICAL EXAMINATION OF WATER

E-mail : phedregionallabjodhpur@gmail.com Web.: indiawater.gov.in Phone No. 0291 – 2651767

No.Lab/Tech./ 2023-24/ 788

Date: 30-03-2024

To,

CAREER POINT WORLD SCHOOL
 VIJAYRAJE NAGAR, NEW HIGH
 SHATABDI CIRCLE, JHALAMAND
 JODHPUR

District : Jodhpur

Not for Legal Purpose

Tehsil :

Sample Collected by - Vinod

SAMPLE WAS NOT COLLECTED

BY THE LABORATORY

Reference : NIL Date: 27.03.2024


Date of Collection: 28.03.2024

Date of Receipt: 28.03.2024

Date of Examination: 30.03.2024

Lab Sample No.	Source&Location	Desirable Limit as per IS 10500 :2012	Permissible Limit in absence of alternate source	PC-49
	Village - Code No. -			R.O CAREER POINT WORLD SCHOOL JHALAMAND JODHPUR
1	pH	6.5 - 8.5	6.5 - 8.5	7.5
2	Turbidity (NTU)	1	5	0.0
3	Colour (TCU)	5	15	0.0
4	Odour	-	-	U.O.
5	Temperature ⁰ C	-	-	-
6	Alkalinity Methyl Orange (as CaCO ₃)	200	600	86
7	Total Hardness (as CaCO ₃)	200	600	96
8	Calcium Hardness (as CaCO ₃)	-	-	50
9	Magnesium Hardness (as CaCO ₃)	-	-	46
10	Carbonate Hardness (as CaCO ₃)	-	-	86
11	Non Carbonate Hardness (as CaCO ₃)	-	-	10
12	Chlorides as Cl ⁻	250	1000	26
13	Sulphate as SO ₄ ⁻²	200	400	-
14	Nitrate as NO ₃ ⁻	45	No relaxation	3
15	Total Dissolved Solids (TDS)	500	2000	204
16	Fluorides as F ⁻	1	1.5	0.2

Note: All results except at Sr No. 1 to 5 are in mg /L


 Superintending Chemist
 P.H.E.D. Regional Lab., Jodhpur

No. _____
 Copy forwarded to the Chief Chemist PHED Raj. Jaipur

Date: _____

Superintending Chemist
 P.H.E.D. Regional Lab., Jodhpur